

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for MILTON WATER, WV3300609

Our water system violated drinking water monitoring requirements within the past year. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation.

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During periods listed in the table below, we did not monitor or test as required and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the monitoring we did not conduct, how often we are supposed to sample and how many samples we are supposed to take, and when the samples should have been taken.

Required Monitoring	Required Monitoring Frequency	When all samples should have been taken
Failure to Maintain Adequate Operator Coverage (Type 12)		August 2018
Trihalomethanes/Haloacetic Acids (Type 27)	Quarterly	3 rd QTR 2018, 2 nd QTR 2018
Total Organic Carbon (Type 27)	Quarterly	2 nd QTR 2018
Monthly Operational Report – Chlorine/Turbidity (Type 38)	Monthly	August 2018, July 2018, June 2018

What happened? What is being done? (Describe corrective action)

During a period of transition between water operators, the monitoring listed above was overlooked, as the new operators believed the previous operator had complied with these requirements. However, we have since hired one part-time operator, and three full-time operators. The new operators were made aware of these requirements and have since complied fully.

For more information, please contact Jeff Miller at 304-743-3821
(Contact Name) (Phone Number)
or 1139 Smith Street, Milton, WV 25541
(Mailing Address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by MILTON WATER

State Water System ID# WV3300609

Date Distributed January 31, 2019